



UK - Declaration of Conformity

Manufacturer: Bender GmbH & Co. KG

declare under our sole responsibility that the product

Product name: Insulation monitoring device isoCHA425 (see annex)

to which this declaration relates, is in conformity with the following UK legislations.


Legislations:	RoHS Regulations 2012	S.I. 2012/3032
	EMC Regulations 2016	S.I. 2016/1091
	Electrical Equipment (Safety) Regulations 2016	S.I. 2016/1101

The assessment of this product has been based on the following standards:


Applied standards :

EN 61010-1	:2010 + A1:2019 + A1:2019/AC:2019
EN 61326-2-4	:2013
EN 61557-1	:2007
EN 61557-8	:2015
EN IEC 63000	:2018
IEC 61851-1	:2017
IEC 61851-23	:2023 (ED2)

Grünberg, 18.04.2024



(H. Nowicki, CSO)



(i.V. J. Schäfer, Quality Manager)

Remark:

The annexes are part of this UK declaration.
Limitation of standards are marked with an asterisk (*) in the attached type list.

Annex - Typelist of UKCA-declaration isoCHA425

Product group	Art.-no.	Device type
isoxx425	B71036394	isoCHA425HV-D4-4 nur in Verbind. mit AGH
isoxx425	B71036395	isoCHA425-D4-4 DC 50...500 V
isoxx425	B71036396	isoCHA425HV-D4-4+AGH420-1
isoxx425	B71036399	isoCHA425HV-D4-4+AGH421-1
isoxx425	B91036394	isoCHA425HV-D4-4 nur in Verbind. mit AGH
isoxx425	B91036396	isoCHA425HV-D4-4+AGH420-1